




Council of Enviro Excellence

**The CEE 3rd National Power-Gen
Water Management Awards 2025**



MTPS, TATA Power Company Limited, Mundra
(Formerly Known as Coastal Gujarat Power Limited)




CASE STUDY:

Reduction in service water consumption using IOT based water management SCADA



Product	Electricity
Type of organisation	Large Business Organisation (LBO)
Location	Tunda village at Mundra, Kutch district, in Gujarat, India
Capacity	4150 MW (5x830)
Technology	Supercritical
Area	1300 Hectare
Coal source	Imported coal
Water source	Sea water
COD	All 5 units during March 2012 to March 2013.



Beneficiaries	Gujarat	1805
	Maharashtra	760
	Punjab	475
	Haryana	380
	Rajasthan	380



IMS Certification & NABL Accreditation

IRCLASS
SYSTEMS AND SOLUTIONS PRIVATE LIMITED

CERTIFICATE OF APPROVAL
Issued by Indian Register Quality Systems
(A Division of IRCLASS Systems and Solutions Private Limited)

This is to certify that the Occupational Health & Safety Management Systems of

Organisation: The Tata Power Company Limited

Address: Mundra Thermal Power Station,
Ultra Mega Power Plant,
Tunda - Vandh Road,
Tunda Village, Mundra,
Kutch - 370435, Gujarat, India

has been assessed and found conforming to the following requirement

Standard: ISO 45001:2018

Scope: Generation and Supply of Electricity
through Operation and Maintenance of
Coal based Ultra Mega Power Plant

Certificate No.: IRQS/230400792

Initial Certification Date : 04/07/2014
(OHSAS)

Current Date of Granting : 01/07/2023

Expiry Date : 01/07/2026

Shashi Nath Mishra
Head IRQS

This approval is subject to continued satisfactory maintenance of the Occupational Health and Safety Management Systems of the organization to the above standard which will be monitored by IRQS. The use of the Accreditation Mark indicates accreditation with respect to activities covered by the certificate with accreditation no. 0071, Condition Overleaf. 004/IRQS/MS/EN/2018/00

Head Office: 52A, Adil Shankaracharya Marg, Opp.Powal Lake, Powai, Mumbai - 400 072, India.

IRCLASS
SYSTEMS AND SOLUTIONS PRIVATE LIMITED

CERTIFICATE OF APPROVAL
Issued by Indian Register Quality Systems
(A Division of IRCLASS Systems and Solutions Private Limited)

This is to certify that the Quality Management Systems of

Organisation: The Tata Power Company Limited

Address: Mundra Thermal Power Station,
Ultra Mega Power Plant,
Tunda - Vandh Road,
Tunda Village, Mundra,
Kutch - 370435, Gujarat, India

has been assessed and found conforming to the following requirement

Standard: ISO 9001:2015

Scope: Generation and Supply of Electricity
through Operation and Maintenance of
Coal based Ultra Mega Power Plant

Certificate No.: IRQS/230100790

Initial Certification Date : 04/07/2014

Current Date of Granting : 01/07/2023

Expiry Date : 01/07/2026

Shashi Nath Mishra
Head IRQS

This approval is subject to continued satisfactory maintenance of the Quality Management Systems of the organization to the above standard which will be monitored by IRQS. The use of the Accreditation Mark indicates accreditation with respect to activities covered by the certificate with accreditation no. 0071, Condition Overleaf. 004/IRQS/MS/EN/2018/00

Head Office: 52A, Adil Shankaracharya Marg, Opp.Powal Lake, Powai, Mumbai - 400 072, India.

IRCLASS
SYSTEMS AND SOLUTIONS PRIVATE LIMITED

CERTIFICATE OF APPROVAL
Issued by Indian Register Quality Systems
(A Division of IRCLASS Systems and Solutions Private Limited)

This is to certify that the Environmental Management Systems of

Organisation: The Tata Power Company Limited

Address: Mundra Thermal Power Station,
Ultra Mega Power Plant,
Tunda - Vandh Road,
Tunda Village, Mundra,
Kutch - 370435, Gujarat, India

has been assessed and found conforming to the following requirement

Standard: ISO 14001:2015

Scope: Generation and Supply of Electricity
through Operation and Maintenance of
Coal based Ultra Mega Power Plant

Certificate No.: IRQS/230300791

Initial Certification Date : 04/07/2014

Current Date of Granting : 01/07/2023

Expiry Date : 01/07/2026

Shashi Nath Mishra
Head IRQS

This approval is subject to continued satisfactory maintenance of the Environmental Management Systems of the organization to the above standard which will be monitored by IRQS. The use of the Accreditation Mark indicates accreditation with respect to activities covered by the certificate with accreditation no. 0071, Condition Overleaf. 004/IRQS/MS/EN/2018/00

Head Office: 52A, Adil Shankaracharya Marg, Opp.Powal Lake, Powai, Mumbai - 400 072, India.

National Accreditation Board for
Testing and Calibration Laboratories

CERTIFICATE OF ACCREDITATION

**CHEMICAL LABORATORY - MUNDRA THERMAL POWER
STATION, THE TATA POWER COMPANY LIMITED**

has been assessed and accredited in accordance with the standard

ISO/IEC 17025:2017

**"General Requirements for the Competence of Testing &
Calibration Laboratories"**

for its facilities at

CGPL PLANT, UMPP MUNDRA, TUNDA, MUNDRA, KACHCHH, GUJARAT, INDIA

in the field of

TESTING

Certificate Number: TC-11544

Issue Date: 10/11/2024

Valid Until: 09/11/2028

This certificate remains valid for the Scope of Accreditation as specified in the annexure subject to continued satisfactory compliance to the above standard & the relevant requirements of NABL.
(To see the scope of accreditation of this laboratory, you may also visit NABL website www.nabl-india.org)

Name of Legal Entity: THE TATA POWER COMPANY LIMITED

Signed for and on behalf of NABL

N. Venkateswaran
Chief Executive Officer






Background

Mundra thermal power station (MTPS), Tata Power is first supercritical plant in India operating with 100% sea water application. It consumes service water for various purposes including fire water for fire fighting. It also uses DM water for steam generation. Both service water and DM water are derived from sea water. Service water used at MTPS contains high chlorides approx. 500 PPM. However, at design stage no protective layer has been considered for inner surface of pipelines.

Due to above design limitation, MTPS was experiencing daily consumption of up to 13,000 m³ per day due to various leakages both in service water and fire water system. Due to above leakages, MTPS taken frequent complete shutdown of service and fire water system to attend the leakages.



10000m³/Day



Replacement Of Entire Fire and Service Water System Pipelines

Capex Provision = Rs 45 cr
Entire service water network cover 32 KM
Fire water network cover 19.88 KM



Change of Material


Internal Coro-coating and material of construction change from mild steel to carbon steel,







Relocation

Modified service water and fire water from underground to above ground and provided sectional isolation valves for early detection of leakage and immediate maintenance work without complete shutdown of fire and service water system

Notification in FW & SW System (Before SCADA)- YoY




SW Consumption (Before SCADA)



SW Consumption- Target Setting




FY 17-18




Total Running Units		1	2	3	4
■	Average Production	9719	10510	10897	11116.7428
■	Average Consumption	9939	9296	10902	11018.37

FY 18-19




Total Running Units		1	2	3	4
■	Average Production	10512	12223	11828	11409
■	Average Consumption	11006	11935	11972	10929

FY 19 - 20




Total Running Units		1	2	3	4	5
■	Average Production	8397	8254	8493	8808	9265
■	Average Consumption	6843.2	8165.87	8574	8895	9200

FY 20 - 21



Total Running Units		1	2	3	4	5
■	Average Production	6693	6691	8538	8369	8877
■	Average Consumption	6411	7819	8438	8379	8881



MTPS, Tata Power has taken a target to
reduce Service water consumption to

8000m³/day

when 5 units are in service.


Charter Details

Productivity

Environment

Safety

Cost



Improvement Category



Base level

Average Station Service water Consumption = 8500m³

Target level

Average Station Service water Consumption = 8000m³

Actual Saving

Average Station Service water Consumption < 7000m³

Trigger for Improvement

- Department Targets
- KPI Improvement

Methodology of Improvement

- Brainstorming
- Structured Process Review

EPM

07.11.01

Thermal Power Plant Operation

Project/Task Start date : 5-Feb-22

Project/ Task Finish date : 31-Mar-22



1	Main Control Building	10	Electro Chlorination Plant (ECP)
2	Technical Building	11	Compressor House
3	Boiler Unit 10-50	12	Cooling water Pump House (CWPH)
4	TG Hall Unit 10-50	13	Cooling water Intake channel
5	Transformer Yard Unit 10-50	14	Fuel Oil Pump House (FOPH)
6	400KV Switchyard	15	Ash Handling Plant
7	Cooling Water Outfall Channel	16	Internal Coal Handling System (ICHS)
8	Hydrogen Plant	17	RO & DM Plant
9	Fly Ash handling System	18	Project Office


33 km
of Service water
Pipeline
1300-hectare Land

Water Management SCADA



FIRE WATER SYSTEM

SERVICE WATER SYSTEM



Electromagnetic Flowmeter **3**


Ultrasonic Flowmeter **12**

Water Management SCADA



FIRE WATER SYSTEM

SERVICE WATER SYSTEM



Electromagnetic Flowmeter **3**



Ultrasonic Flowmeter **12**

Water Management SCADA



FIRE WATER SYSTEM

SERVICE WATER SYSTEM



Electromagnetic Flowmeter **3**
 Ultrasonic Flowmeter **12**

Water Management SCADA

Realtime Monitoring from anywhere Everywhere



Measure

“Zone wise water Consumption Measurement”



Monitor


“Monitoring all Transmitter in one place”



Control

“Real time alert for high consumption. Take action to reduce consumption.”

“If you can't measure it, you can't manage it”





Alarm Configuration


Alarms are configured in all flow meters at predefined values

Deviation analysis

Analysis of individual flow meters consumption can be done through charts/graphs, Daily Weekly Automated Reports

Electromagnetic & ultrasonic flowmeters

3 Electromagnetic & 12 ultrasonic flow meters with high accuracy are installed for more accurate readings



Water SCADA Dashboard

Dashboard facilitates day wise comparison of flow meter deviation

Triggering of message alarm

Automated message to area owners gets triggered when consumption is more than alarm limit

Cloud server

It is working on independent cloud server

Automated Trigger of alarms




Daily Fire & Service water usage report mail

All SCE & HOD



Use of Data Analysis in water management SCADA

All flow Meter values are analyzed , Consumption Data are compared with previous day values, Erratic & High-water consumption zones were easily identified & Suitable steps taken to reduce water consumption




SW Consumption (After SCADA)-FY22



Average of Service Water Consumption (M3) by Date




Statistic	Value
Data Values	341
Maximum	11468
Mean	6158
Minimum	3615



SW Consumption (After SCADA)-FY23



Statistic	Value
Data Values	365
Maximum	8980
Mean	5864
Minimum	2858




Water Management SCADA- Savings FY-23 (June-22 to March-23)



● Before Water SCADA Implementation (Apr 21-May 22)

● After Water SCADA Implementation (Jun 22-March 23)

Daily Average Service water Consumption (m³)



Total Saving in FY-23 after Implementation of water management SCADA is Rs 68 lakh (in 258 Days)


Water Management SCADA- Savings FY-24 (1 Apr-23 to 31 March-24)



● Before Water SCADA Implementation (Apr 21 to May 22)

● After Water SCADA Implementation (Apr 23 to Mar 24)

Daily Average Service water Consumption (m³)



Total Saving in FY-24 after Implementation of water management SCADA is Rs 1.88 Cr (in 351 Days)

Total costing incurred for implementation of water management SCADA at MTPS is Rs 25.49 lakhs.



Water Management SCADA


Measurement, Analyze, Report, Correction,

APC Reduction

30 KW APC reduction per day which is equivalent to 7.74 MW power saving in FY23 since implementation of Water management SCADA at MTPS.

Reduction of Specific Power Consumption of RO & DM Plant

Reduction in specific power consumption from 3.87 KWH/m³ to 3.85 KWH/m³.



Sustainable development goal

SDG 6 & SDG 12

Under SDG 6 Clean Water & Sanitation & SDG 12 saving natural resources by reducing service water consumption.



System Availability

Frequent isolation of fire and service water system is avoided leading to increased availability of system

Tangible

Intangible

Thank You!

Website: www.tatapower.com

Email Id: navendu.padhy@tatapower.com

Contact: 9227856226



Disclaimer: The contents of this presentation are private & confidential.
Please do not duplicate, circulate or distribute without prior permission.